
LIST OF FIGURES

<u>FIGURE</u>	<u>FIGURE DESCRIPTION</u>	<u>PAGE</u>
1.2.1	Typical Solar Domestic Hot Water System	3
1.3.1	Collector Efficiency	5
1.4.1	Evacuated Tube Collector	10
2.2.1	Heat Exchanger Penalty	13
2.2.2	Temperature Distribution in a Copper Fin (End View)	15
2.2.3	Molecular Structure of a Thermo-Elastomer	16
2.3.1	Energy Balance on Fins	17
2.3.2	One-Dimensional Model Configuration	18
2.3.3	Energy Transferred to Water	24
2.3.4	Reduction in Integration Length due to Fin and Tube Thickness	25
2.4.1	Temperature Distribution	27
2.4.2a	Temperature Distribution with $k = 1 \text{ W/m-K}$	27
2.4.2b	Temperature Distribution with $k = 10 \text{ W/m-K}$	28
2.4.2c	Temperature Distribution with $k = 400 \text{ W/m-K}$	28
2.4.2d	Temperature Distribution with $k = \infty \text{ W/m-K}$	29
2.5.1	Comparison between One and Two Dimensional Models (0.1-0.5 cm)	30
2.5.2	Comparison between One and Two Dimensional Models (0.1-0.9 cm)	31

2.6.1	Collector Efficiency Factor for a Range of $k\delta$	32
2.6.2	Collector Heat Removal Factor for a Range of $k\delta$	34
2.6.3	Model Verification for Standard Configuration	35
2.7.1	Monthly Solar Fraction for 2.6 m ² Thermo-Elastic Versus 1.76 m ² Model AE-21 Collector	37
2.7.2	Square Tube Thermo-Elastic Collector Plate Design	40
3.3.1	Economic Parameters (from <i>f</i> -Chart version 5.88W)	48
3.4.1.1a	Four-Season System Sensitivity to Slope in Madison, WI	51
3.4.1.1b	Four-Season System Sensitivity to Slope in Miami, FL	51
3.4.1.1c	Four-Season System Sensitivity to Slope in Seattle, WA	52
3.4.1.1d	Four-Season System Sensitivity to Slope in Albuquerque, NM	52
3.4.1.2a	Three-Season System Sensitivity to Slope in Madison, WI	54
3.4.1.2b	Three-Season System Sensitivity to Slope in Miami, FL	54
3.4.1.2c	Three-Season System Sensitivity to Slope in Seattle, WA	55
3.4.1.2d	Three-Season System Sensitivity to Slope in Albuquerque, NM	55
3.4.2.1	Life Cycle Savings Sensitivity to Collector Azimuth for Various SDHW Configurations	58
3.4.2.2	Annual Solar Fraction Sensitivity to Collector Azimuth for Various SDHW Configurations	59
3.4.3.1	Collector Efficiency Curves	60
3.4.3.2a	Three-Season LCS Sensitivity to Slope and Area in Madison, WI, (AE-32 Collector, $C_A=220$ \$/m ²)	61
3.4.3.2b	Three-Season LCS Sensitivity to Slope and Area in Madison, WI, (ASN-45A Collector, $C_A=170$ \$/m ²)	62
3.4.3.3a	Three-Season LCS Sensitivity to Slope and Area in Miami, FL, (AE-32 Collector, $C_A=220$ \$/m ²)	63

3.4.3.3b	Three-Season LCS Sensitivity to Slope and Area in Madison, WI, (ASN-45 Collector, $C_A=170 \text{ \$/m}^2$)	63
3.4.3.4a	Four-Season LCS Sensitivity to Slope and Area in Albuquerque, NM, (AE-32 Collector, $C_A=220 \text{ \$/m}^2$)	64
3.4.3.4b	Four-Season LCS Sensitivity to Slope and Area in Albuquerque, NM, (ASN-45 Collector, $C_A=170 \text{ \$/m}^2$)	65
3.5.1	Effect of Altering Area Independent Cost	69
3.5.2	Three-Season System Design Methodology	70
3.5.3	LCS System Design for Madison, WI	71
3.5.4	LCS System Design for Seattle, WA	72
3.5.5	LCS System Design for Miami, FL	72
3.5.6	LCS System Design for Albuquerque, NM	73
3.6.1	Payback Period System Design for Madison, WI	76
3.6.2	LCS System Design for Seattle, WA	76
3.6.3	LCS System Design for Miami, FL	77
3.6.4	LCS System Design for Albuquerque, NM	77
3.6.5	The Effect of System Prices upon Critical Area	79
3.6.6	The Effect of Various Electricity Prices upon Critical Area	80
4.2.1	Water Heating System Schematic Modeled by f -Chart	85
4.2.2	f -Chart Correlation	89
4.4.1a	Four-Season System f -Chart Inputs	94
4.4.1b	Three-Season System f -Chart Inputs	95
4.4.2	Comparison between Equation Solver Results and f -Chart Results	96
4.6.1	Thermal Performance of a Three-Season System Based on A Four-Season System Meeting 25% of the Annual Load	

x		
	(Western United States)	104
4.6.2	Thermal Performance of a Three-Season System Based on A Four-Season System Meeting 25% of the Annual Load (Eastern United States)	105
4.6.3	Thermal Performance of a Three-Season System Based on A Four-Season System Meeting 50% of the Annual Load (Western United States)	106
4.6.4	Thermal Performance of a Three-Season System Based on A Four-Season System Meeting 50% of the Annual Load (Eastern United States)	107
4.6.5	Thermal Performance of a Three-Season System Based on A Four-Season System Meeting 75% of the Annual Load (Western United States)	108
4.6.6	Thermal Performance of a Three-Season System Based on A Four-Season System Meeting 75% of the Annual Load (Eastern United States)	109
5.3.1	TRNSYS System Model	118
5.3.2	Two Controller Decision Making Process	121
6.4.2	EUSESIA Analysis Output for a Four-Season SDHW Installation	135
6.4.3	EUSESIA Analysis Output for a Three-Season SDHW Installation	136