

**Optimized Combined Operation of a Cooling
Pond and Cooling Tower System for Condenser Cooling
at a Steam Cycle Power Plant**

by

Jörg Kirchhoff

A thesis submitted in partial fulfillment of
the requirements for the degree of

Master of Science
(Mechanical Engineering)

at the

University of Wisconsin - Madison
1995

Abstract{ TC "Abstract" \l 1 }

The performance of the condenser cooling cycle of a steam cycle power plant is examined for the Columbia Generating Station of the Wisconsin Power & Light Company located near Portage, Wisconsin. The Columbia station is a coal fired power plant with a capacity of 1000 MW. A closed circuit cooling system is used for heat rejection that consists of a cooling pond and two cooling towers. Pond and towers are connected in a parallel arrangement.

To study the behavior of the cooling system, computer models of the components are developed. The cooling tower model is based on the analogy approach of a cooling tower and an heat exchanger. An effectiveness-Ntu method is employed to predict the cooling tower performance with respect to ambient and load conditions. For the calculation of cooling capacity of the cooling pond surface, a semi-empirical approach is selected that is based on the combination of free and forced convection. The water flow in the pond is approximated by a plug flow model. From the energy transfer and flow model a simulation program is developed that is capable of predicting cooling pond temperatures dependent on meteorological conditions and heat load on the pond.

The possibility of adding different cooling devices to the system is examined. A simple model of an atmospheric cooling spray is employed. A comparison between cooling tower and cooling spray performance is performed to study if the addition of a cooling spray can be an advantage for the system performance. The impact of dredging the pond to a greater depth is evaluated.

To link the cooling system to the steam cycle performance a condenser model is introduced that predicts the condenser back pressure for a given circulating water temperature and plant

load. From an empirical relation the influence of condenser back pressure on the steam cycle heat rate is determined. The performance of the cooling system is then evaluated economically.

The modular system simulation program TRNSYS is used to analyze the behavior of the cooling system in combination with the power generation unit. Transient simulations are performed in hourly time steps to examine the impact of weather conditions on the whole system and to study diurnal fluctuations. A simulation program usable by the plant operators is a product of this work.

Using the simulation program the cooling system is examined under different operation modes utilizing the available equipment. Dependent on weather conditions the best plant operation mode is found. Recommendations are given for the most cost effective alteration of the cooling towers and pond.

Acknowledgments{ TC "Acknowledgments" \l 1 }

Special Thanks go to my advising professors Prof. William A. Beckman and Prof. John W. Mitchell who guided me through this work and helped me to understand and solve the many problems I encountered. Without their support my stay at the Solar Energy Lab and the success in working on this project would not have been possible.

I am very grateful for the support of the German Academic Exchange Service (DAAD) that supported my stay at the University of Wisconsin. I also appreciated the support from the Institut für Thermodynamik and from the Institut für Fabrikanlagen at the Universität Hannover, which organized and guided the exchange program.

Thanks also to Eric Sandvig and the people from the Wisconsin Power & Light Company, who put confidence in my skills and supported my work on this project. I learned a lot from the close cooperation and I really enjoyed the time being at the plant site, getting some physical meaning for the numbers on the computer screen.

I really enjoyed the time at the Solar Lab, thanks to the professors and the students working there. I never experienced such a stimulating working atmosphere before. We could discuss work problems and as well have a lot of fun. Thanks to all of you for the good time we had together.

Special thanks go to my parents who supported me during my whole stay in Madison, not only financially but with a great amount of understanding and encouragement. Also special thanks for my brother and sister, Marc and Nicole, who helped wrapping up many care packages for Christmas and other opportunities.

I especially want to thank my friends at home, who did not forget me in this one and a half year long stay abroad. Thanks for keeping in touch with me and encouraging me to this step. I appreciated your calls and letters and the many visitors I could welcome. Thanks for never letting me feel that there was a big distance between us.

I want to thank Prof. Ray Brown and his wife Eleonore, who became a kind of a second family for me. I promise to keep in touch and hope we will meet again.

Table of contents{ TC "Table of contents" \l 1 }

Abstract	iii
Acknowledgments	v
Table of contents	vii
List of figures	xiv
Nomenclature	xvii

Abstract

Acknowledgments

Table of contents

List of figures

Nomenclature

Introduction

Error! No table of contents entries found.

Abstract

Acknowledgments

Table of contents

List of figures

Nomenclature

Detailed System Description

Error! No table of contents entries found.

Abstract

Acknowledgments

Table of contents**List of figures****Nomenclature****Data Acquisition**

Abstract iii

Acknowledgments v

Table of contents vii

List of figures xii

Nomenclature xv

Modeling of Components

Abstract iii

Acknowledgments v

Table of contents vii

List of figures xi

Nomenclature xiv

Impact of Cooling Cycle on Power Plant Performance

Error! No table of contents entries found.

Abstract**Acknowledgments****Table of contents****List of figures****Nomenclature****System Simulation**

Error! No table of contents entries found.

Abstract

Acknowledgments

Table of contents

List of figures

Nomenclature

Conclusion and Recommendation

Error! No table of contents entries found.

Abstract	iii
Acknowledgments	v
Table of contents	vii
List of figures	x
Nomenclature	xiii

List of figures{ TC "List of figures" \l 1 }

Figure Description

Error! No table of contents entries found.3.3

Frequency of Wind Direction at the Columbia Station50

Error! No table of contents entries found.4.10

Make-up inflow addition112

Error! No table of contents entries found.

Nomenclature{ TC "Nomenclature" \l 1 }

Roman Symbols

a	surface area of droplet
$a_1,..a_5$	curve fit coefficients for heat rate correction
A	surface area
A_A, B_A	curve fit coefficients for base auxiliary cooling
A_{bo}, B_{bo}	curve fit coefficients for boiler efficiency
$A_H, B_H,$	curve fit coefficients for standard heat rate
C_H	
A_L, B_L	curve fit coefficients for steam flow rate
A_S, B_S	curve fit coefficients for subcooling
A''	heat transfer surface area per unit volume
c	tower coefficient, operation cost
c_p	specific heat of air
c_{pw}	specific heat of water
c_s	derivative of enthalpy of air with respect to temperature along saturation line
C	infrared cloud amount
$C_1..C_4$	correction coefficients for condenser heat transfer calculation
C_D	drag coefficient
C_R	dimensionless convection ratio
dHR_{pb}	heat rate correction due to back pressure
D	droplet diameter
D_{AB}	binary diffusion coefficient
D_C	distance between clusters in one row
D_R	distance between spray rows

D_S	rectangular length of spray cluster	
ΔT_{sub}	subcooling temperature difference	
ΔT_m	logarithmic mean temperature difference	
ΔT_w	cooling water temperature rise in condenser	
D_{vs}	Sauter mean diameter	
\dot{E}_w	evaporative energy flux	
\dot{E}_e	evaporative energy flux per unit volume	
f_v	wind function	
f	fuel cost	
g	gravitation constant	
GHR	gross station heat rate	
GTHR	gross turbine heat rate	
GSTH	gross turbine standard heat rate	
h_a	enthalpy of air	
h_c	heat transfer coefficient	
h_{cl}	cloud base height	
h_{con}	condensate enthalpy	
h_0	reference height for cloud emissivity calculation	
h_{ex}	exhaust steam enthalpy	
h_{fg}	latent heat of vaporization	
h_m	mass transfer coefficient	$\frac{\text{ft}}{\text{s}}$
$h_{s,\text{eff}}$	effective surface enthalpy	
h_w	enthalpy at saturation at water surface temperature	
I	solar radiation on horizontal surface	
K	mass transfer coefficient	$\frac{\text{lb}}{\text{ft}^2 \cdot \text{s}}$
L	characteristic length	

L_C	length of cluste leg
L_R	length of spray row
Le	Lewis number
m	exponent for relation of Nusselt numbers
\dot{m}_a	mass flow rate of air
m_d	droplet mass
\dot{m}_e	mass flow associated with evaporation
\dot{m}_e''	mass evaporative mass flux per unit surface area
\dot{m}_e'''	evaporative mass flux per unit volume
\dot{m}_{ex}	exhaust steam flow
\dot{m}_{th}	main throttle steam flow rate
\dot{m}_w	water mass flow rate
$\dot{m}_{w,c}$	cooling wate flow rate in condenser
m^*	capacitance rate
\dot{m}_w'	water flow rate per unit length of spray canal
n	tower coefficient
$n_{lh,av}$	average number of low head cycle pumps
$n_{lh,sum}$	sum of operation hours of low head pumps
$n_{lh,sum}$	number of hours in month
NHR	net staion heat rate
NHR_c	net heat rate without auxiliary power
NHR_{st}	net heat rate at standard condition
$NTHR$	net turbine heat rate
Ntu	number of transver units
NU_d	Nusselt number for a droplet
p	partial water vapor pressure

P_{atm}	atmospheric pressure
p_b	back pressure
p_s	saturation water pressure at surface temperatur
p_a	water vapor pressure in ambient air
P	perimeter
P_{net}	net station power
P_{gr}	gross turbine power
$P_{\text{aux,b}}$	base auxiliary power
$P_{\text{aux,c}}$	auxiliary power due to cooling
Pr	Prandtl number
P_{st}	load at standard conditions
q	energy transfer per unit surface area
\dot{Q}_{cyc}	rate of heat added to steam cycle
\dot{Q}_{st}	rate of heat added to steam generator
\dot{Q}	energy tansfer rate
Q'	heat transfer per unit length of spray field
r_c	fraction of sky covered with clouds
r_m	mass flow ratio of exhaust steam to cooling water
r_{st}	fraction of main steam that enters condenser
r_T	ratio of wate temperature rise over logarythmic mean temperature difference
Ra	Rayleigh number
R_B	Bowen ratio
Re	Reynolds number
R_S	radius of spray pattern
Sc	Schmidt number
Sh	Sherwood number

t_f	flying time
T	temperature
T_a	local air temperature
T_c	temperature at which heat is rejected in power plant
T_h	temperature at which heat is added to steam cycle
T_{db}	drybulb temperature
T_{shell}	condenser shell temperature
T_V	virtual temperature
T_{wb}	wetbulb temperature
T_w	water temperature
u	relative velocity between droplet and air
U	heat transfer coefficient for pond equilibrium temperature
UA	overall heat transfer coefficient
U_i	internal energy
v_1, v_2	wind velocity at different heights
v_{av}	average wind velocity over spray height
v_d	horizontal droplet velocity
v_{inf}	wind speed, measured at weather station
v_{wat}	water velocity in condenser tubes
V_d	volume of water droplet
V	volume
w	humidity ratio of local air
w_a	humidity ratio of ambient air
w_d	vertical droplet velocity
$w_{s,eff}$	effective saturation humidity ratio
w_w	humidity ratio at saturation at water surface temperature

W	width of spray field
X_{cal}	calibraion constant
z_1, z_2	measurement heights of wind speed
Z_u, Z_s	droplet flying heights
Z_T	reference height for wind velocity measurement

Greek Symbols

α	thermal diffusivity
β	expansion coefficient
ε	effectiveness, emissivity
ε_{boi}	boiler efficiency
ε_0	clear sky emmissivity
ε_h	diurnal correction factor for sky emissivity
ε_e	elevation correction for emissivity
ε_{cl}	corrected clear sky emissivity
ε_{sky}	overall sky emissivity
ε_c	cloud emissivity
ε_w	water surface emissivity
Γ	factor for cloud base height
η_c	Carnot efficiency
κ	power law exponent
ρ_w	density of water
$\rho_{w,s}$	density of water vapor at saturaion at water temperature
$\rho_{w,inf}$	density of water vapor in ambient air
σ	Stefan Boltzmann constant, $\sigma = 1.729 \cdot 10^{-9} \frac{\text{Btu}}{\text{ft}^2 \cdot \text{hr} \cdot ^\circ \text{R}}$
τ	time

μ	dynamic viscosity
ν	kinematic viscosity
Ψ	angle of approach of wind velocity to spray field

Additional Subscripts

c	characteristic
C	cold
com	combined
conv	convection
concondenser	
D	droplet
E	equilibrium
el	element
ev	evaporation
for forced	
free	free
ground	ground
H	hot
in	inlet
L	lake
mu make up	
out outlet	
s	saturation at water surface temperature
spray	spray
sol solar	
rad,sky	radiation from sky
rad,w	radiation from water surface

w water