
APPENDIX B

TRNSYS SIMULATIONS

TRNSYS Deck of System Size #2 With 2 Tank Configuration (w/ PV pump)

```

ASSIGN C:\KEARY\ANNUAL\SYS2.LST                                6
ASSIGN C:\KEARY\ANNUAL\Hsys2PV.out                            13
ASSIGN C:\KEARY\ANNUAL\WTHR91.DAT                             14
ASSIGN C:\KEARY\ANNUAL\91DRAWS.dat                            15
ASSIGN C:\KEARY\ANNUAL\MLKMAIN.DAT                            16
ASSIGN C:\KEARY\ANNUAL\Dsys2PV.OUT                            17
ASSIGN C:\KEARY\ANNUAL\Msys2PV.OUT                            18
* 52 GALLON TANK B.U. for System #2 W/PV
* * * * *
*
*           Analysis of Average Water Loads                    *
*           An Annual 1991 Analysis                            *
*           for Demand Reduction of SDHW Systems               *
*           Milwaukee, WI WEPCo Utility                       *
* * * * *
EQUATIONS 26
START=0.00
STOP=8760
STEP=1./6
TENV=18.0
TSET=60.0
*Solar TANK SIZE IN ACTUAL 80 GALLONS=>(3.7854*10^-3 m^3/1 gal)
TSIZE=0.302832
HGHT=1.2192
NODES=5
AREA=6.00
TI=6.9
*uloss is needed for the tank evaluation in kJ/HR-M2-C SO DIVIDE
*BY THE SURFACE AREA OF THE SOLAR GALLON TANK @ SAME STANDBY
LOSS
* WHICH YIELDS %/HR*DENS*Cp/2*PI*R*H =>KJ/HR-M2-C
ULOSS=3
*fractional loss is the (%/hour) rating for different dhw's
FRCTLOSS=0.7
*STANDBYLOSS=FRCLOSS(%/HR)/100%*VOL(GAL)*8.34(LB/GAL)*T(F)*1(BTU/
LB-F)
*STNDBY=KJ/HOUR =>(%/HR)/(%)*VOL(M3)*DENS(KG/M3)*T(C)*Cp(KJ/KG-C)
*THE bACK-UP TANK SIZE IS 52 GALLONS, WITH ITS ASSOCIATED LOSSES
BUTSIZE=0.19684
STBYLOSS=(FRCTLOSS/100)*(BUTSIZE)*1000*(TSET-TENV)*4.19
DAY=1.0
RHOG=2.0000E-01
SLOPE=2.30000E+01
GAMMAI=0.0000E+0

```

SC=4871
 SHIFT=0.0
 LAT=3.85200E+01
 *TEMPERING VALVE EQUATIONS FOLLOW: SO WATER NOT MORE THAN
 TSET, IT
 *IS MIXED WITH MAINS TEMPERATURE TO DELIVERY AT TSET ONLY.
 * TMAINS IS FROM DATA READER 39 AND CHANGES MONTHLY
 $TDIFF = \text{MAX}(0.000001, ([60,5] - [39,1]))$
 $FLOWRATIO = \text{MIN}(1, ((TSET - [39,1]) / TDIFF))$
 $MLOAD = [29,1] * FLOWRATIO$
 FACT=3.7853
 SCALE=1.0*FACT
 *SCALE IS WHAT THE WATER DRAW IS SCALED BY=>NORMALLY 69.3
 GALLS
 *FACT IS THE CONVERSION FROM GAL/HOUR TO KG/HR

SIMULATION START STOP STEP

Limits 25 25 25
 TOLERANCES 0.001 0.001
 WIDTH 72

UNIT 19 TYPE 9 DATA READER FOR MILKWAUKEE 1991 WEATHER

* 1/1/91 TO 12/31/91 WEATHER
 PARAMETERS 20
 * MODE N dT(HOURS) DUMHOURS Tdb(C) T_wb(C) Wind I(kJ/M2-hr)
 -2 5 1 1 1 0 2 1 0 3 1 0 4 1 0 -5 1 0
 * LU FRMT
 14 0
 *OUTPUTS: 2,Tdb 5,I
 *TRACE 0,24

UNIT 29 TYPE 9 DATA READER FRO WATER DRAWS

*WATER DRAWS: (GAL/HR) - CONVERT TO KG/HR
 * USE FACTOR 3.7853
 PARAMETERS 7
 * MODE N STEP VAR MULT ADD LU FRMT
 2 1 STEP -1 SCALE 0. 15 0
 *OUTPUTS: 1,DRAW(KG/HR)
 *TRACE 0,24

UNIT 39 TYPE 9 DATA READER FOR MILWAUKEE MAINS WATER TEMPERATURE

* CHANGES MONTHLY BUT READ IN DAILY (24 HOURS) FROM F-CHART FILE
 PARAMTERS 8
 * MODE N dT(HOURS) TMAINS LU FRMT

2 1 24 -1 1 0 16 0
 *OUTPUTS: 1, TMAINS

UNIT 16 TYPE 16 RADIATION PROCESSOR

PARAMETERS 8

* RADMODE TRACKMODE TILTMODE DAY LAT SC SHIFT SMOOTH

3 1 1 DAY LAT SC SHIFT 2

INPUTS 6

* I(kJ/m²-hr) td1 td2 RHOG BETA1 GAMMAI INext 19,5 0.0

19,5 19,19 19,20 RHOG SLOPE GAMMAI 19,25

0.0 0.0 0.0 RHOG SLOPE GAMMAI 0.0

*OUTPUTS: 1,Io 2,THETAz 3,GAMMAz 4,I 5,Id 6,IT1 7,IbT1 8,IdT1 9,THETA1

* 10,BETA1 11,IT1

*TRACE 60,61

UNIT 1 TYPE 1 COLLECTOR

PARAMETERS 14

* MODE N AREA Cp EFFMODE G ao a1 a2 EFF CpHX OPTMODE bo b1

1 1 AREA 4.19 1 50.7 15. 0.0 -1 4.19 1 0.1 0.0

INPUTS 10

* Ti mCOLL(KG/HR) mHX Tamb It I Id RHOG THETA BETA(SLOPE)

3,1 3,2 3,2 19,2 16,6 16,4 16,5 0,0 16,9 16,10

TI 0.0 0.0 20.0 0.0 0.0 0.0 0.7 0.0 40.0

*OUPUTS: 1, To 2,mo 3,Qgain(KJ/HR) 4,Tco

*TRACE 60,61

UNIT 2 TYPE 2 PUMP CONTROLLER

PARAMETERS 4

* NSTK dThigh dTlow Tmax

11 1.0 1.0 100

INPUTS 4

* Th TI TIN GAMMAI

1,1 60,6 0,0 0,0

15. TI TI 0.

*OUTPUTS: 1,GAMMAo (CONTROL FUNCTION)

*TRACE 60,61

UNIT 3 TYPE 3 PUMP

PARAMETERS 4

* mMAX Cp Pmax(KJ/HR) fpar

325. 4.19 100. 0.

INPUTS 3

* Ti mi GAMMA

60,6 60,4 2,1

TI 0.0 0.0

*OUTPUTS: 1,To 2,mo 3,Pfan

UNIT 60 TYPE 60 SOLAR STORAGE TANK

PARAMETERS 43

*NODES MODE VOL H PER H1IN H1OUT H2IN H2OUT CP

NODES 1 TSIZE HGHT -1 0.00 HGHT HGHT 0 4.19

*RHO Ut K KDELTA TBOIL AUXMODE HAUX1 HSTAT1 TSET1

1000 ULOSS 2.0988 0. 100 2 1.155 1.155 TSET

*Udb1 Ldb1 Qaux1 Haux2 HSTAT2 TSET2 Udb2 Ldb2 QAUX2

2 2 0.0 0.495 0.495 TSET 2 2 0.00

*UAflue Tflue HMODE Umode Hhx HXFLUID %GLY ID OD

0.0 TENV 0 0 -0.1 1 0.60 0.1 0.3

*HXAo FINFRAC FINEFF HX_L HX_K NOWARN

0.86 0.73 0.8 4.9 1444 1

INPUTS 12

*M1IN M1OUT M2IN M2OUT TMAINS T2IN TENV GMA1 GMA2 HXIN MHX

C_HX

MLOAD MLOAD 1,2 0,0 39,1 1,1 0,0 0,0 0,0 0,0 0,0 0,0

*29,1 29,1 1,2 0,0 39,1 1,1 0,0 0,0 0,0 0,0 0,0 0,0

0.0 0.0 0.0 -2 6.9 TI TENV 1. 1. 71. -300 0.513

DERIVATIVES NODES

TI TI TI TI TI

*OUTPUTS: 1,MLOAD 2,MLOAD 3,Mcoll 4,Mcoll 5,Tload 6,Tcoll 7,Qenv

* 8,Qin1 9,Qout1 10,Qin2 11,Qout2 12,Qaux2 13,Qaux1 14,Qaux2 15,Qflue

* 16,deltaU 17,Tave 18,dPRESS 19,dPRESS 20,dPRESS 21,dPRESS 22,Qhx

* 23,EB 24,TOUThx 25,LMTDhx 26,UAhx 27=>27+NODES=TNODES

*TRACE 0,24

*UNIT 4 OUTPUTS:

*OUTPUTS: 1,Trtn 2,m_rtnCOLL 3,Tload 4,m_load 5,Qenv,loss 6,Qs

* 7,dEtank 8,Qaux1

UNIT 6 TYPE 6 BACK-UP HEATER FOR SOLAR

PARAMETERS 5

* Qmax(KJ/HR) Tset(C) Cp(KJ/KG-C) UAloss(kJ/hr-C) EFFhtr

9999999. TSET 4.19 0 1

INPUTS 4

* Ti(C) mi(KG/HR) GAMMA Tenv

60,5 60,1 0,0 0,0

TI 0.0 1. 21.0

*OUTPUTS: 1,To 2,mo 3,Qaux(KJ/HR) 4,Qloss 5,Qfluid(kJ/hr)

* THIS HEATER IS THE MODEL FOR THE ELECTRIC ONLY TANK

* MAINS IS HEATED WITH NO STORAGE, LOSSES ARE ACCOUNTED FOR WITH THE

* STANDBY LOSS TERM

UNIT 61 TYPE 6 HEATER

PARAMETERS 5

* Qmax(KJ/HR) Tset(C) Cp(KJ/KG-C) UAlloss(kJ/hr-C) EFFhtr

9999999. TSET 4.19 0 1

INPUTS 4

* Ti(C) mi(KG/HR) GAMMA Tenv

39,1 29,1 0,0 0,0

8.0 0.0 1. 18.0

*OUTPUTS: 1,To 2,mo 3,Qaux(KJ/HR) 4,Qloss 5,Qfluid(kJ/hr)

EQUATIONS 14

*CONVERTING KJ/HR TO KW FOR DEMAND & KG/HR TO GPM WATER DRAW

*FOR FIRST 2 TRIPLE DAYS (0-144) USE FACTOR 3.7853, FOR SINGLE STAT

DRAW=[29,1]/SCALE

PFAN=[3,3]/3600

GAMPUMP=[2,1]

DmdSOL=([6,3]+STBYLOSS)/3600

DmdELC=([61,3]+STBYLOSS)/3600

dTANKLOSS=STBYLOSS/3600

QauxSOL=([6,3]+STBYLOSS)

QauxELC=([61,3]+STBYLOSS)

SF=((QauxELC-QauxSOL)/(QauxELC+0.00000001))*100

*Qaux1=[60,13]/3600

QenvLOSS=[60,7]/3600

QsTANK=([60,10]-[60,11])/3600

Qsolar=[16,4]/3600

Qgain=[1,3]/3600

DRAWS=[29,1]/3.7853

*PRINTS GALLONS/HOUR

*****HOURLY RESULTS*****

UNIT 42 TYPE 24 INTEGRATOR FOR HOURLY ENERGY AND DEMAND

SAVINGS

* PARAMETERS 1: dtR=>TIME INTERVAL FOR Xi'S TO BE INTEGRATED

* Yi's ARE RESET TO 0 AFTER EACH TIME INTERVAL

PARAMETERS 1

* TIME PERIOD TO INTEGRATE OVER

1.0

INPUTS 2

* QauxSOL QauxELC DRAWS

QauxSOL QauxELC DRAW TEST

0.0 0.0 0.0 0.0

*OUTPUTS: 1,QauxSOLhourly 2,QauxELChourly

EQUATIONS 4

* HOURLY DEMAND OF SOLAR & ELECTRIC BACKUP

SOLdmd=([42,1]/3600)

ELCdmd=([42,2]/3600)

SOLsvgs=(SOLdmd-ELCdmd)

SFRACTION=((([24,2]-[24,1])/([24,2]+0.00000001)))*100

UNIT 28 TYPE 25 HOURLY RESULTS PRINTER

*PRINT RUNNING TOTALS DEMAND EVERY HOURS

PARAMETERS 4

* dtp tON tOFF Lunit UNITS

1 START STOP 13

INPUTS 3

SOLdmd ELCdmd SOLsvgs

SOLdmd(kW) ELCdmd(kW) SOLsvgs(kW)

*****DAILY RESULTS*****

UNIT 24 TYPE 24 INTEGRATOR FOR DAILY ENERGY SAVINGS

* PARAMETERS 1: dtR=>TIME INTERVAL FOR Xi'S TO BE INTEGRATED

* Yi's ARE RESET TO 0 AFTER EACH TIME INTERVAL

PARAMETERS 1

* TIME PERIOD TO INTEGRATE OVER

24.0

INPUTS 3

* QauxSOL QauxELC DRAWS

QauxSOL QauxELC DRAWS

0.0 0.0 0.0

*OUTPUTS: 1,QauxSOLdaily 2,QauxELCdaily

*TRACE 0,24

UNIT 25 TYPE 25 DAILY RESULTS PRINTER

*PRINT RUNNING TOTALS OF INTEGRATION RESULTS EVERY 24 HOURS

PARAMETERS 4

* dtp tON tOFF LU UNITS

24 START STOP 17

INPUTS 4

* QauxSOLDAILY QauxELCDAILY SFRACTION DRAWS

24,1 24,2 SFRACTION 24,3

QauxSOL(kJ/DAY) QauxELC(kJ/DAY) SF(%) DRAWS(GAL/DAY)

*****MONTHLY RESULTS*****

UNIT 22 TYPE 24 INTEGRATOR FOR MONTHLY ENERGY SAVINGS

* PARAMETERS 1: dtR=>TIME INTERVAL FOR Xi'S TO BE INTEGRATED

* Yi's ARE RESET TO 0 AFTER EACH TIME INTERVAL

PARAMETERS 1

* TIME PERIOD TO INTEGRATE OVER

-1

INPUTS 3

* QauxSOL QauxELC
QauxSOL QauxELC DRAWS
0.0 0.0 0.0

*OUTPUTS: 1,QauxSOLmonthly 2,QauxELCmonthly

EQUATIONS 1

SFMONTHLY=100*([22,2]-[22,1])/([22,2]+0.000000001)

UNIT 52 TYPE 25 MONTHLY RESULTS PRINTER

*PRINT RUNNING TOTALS OF INTEGRATION RESULTS EVERY MONTH

PARAMETERS 4

* dtp tON tOFF LU UNITS
-1 START STOP 18

INPUTS 4

* QauxSOL QauxELCD SFRACTION DRAWS
22,1 22,2 SFMONTHLY 22,3
QauxSOL(kJ/DAY) QauxELC(kJ/DAY) SF(%) DRAWS(GPH)

END

UNIT 65 TYPE 65 ON-LINE GRAPHICS

PARAMETERS 14

* Ntop Nbot Ymin1 Ymax1 Ymin2 Ymax2 Irefrsh Iupd
3 2 0 5000 0 1.5 1 1

* UNITS Npic Grid Stop SYMBOLS OUT
3 365 4 0 2 0

INPUTS 5

19,5, 16,6 1,3 DmdELC DmdSOL
WEATHRAD PROCCED Qgain(KJ/HR) Delec(kW) Dsol(kW)

end

UNIT 65 TYPE 65 ON-LINE GRAPHICS

PARAMETERS 14

* Ntop Nbot Ymin1 Ymax1 Ymin2 Ymax2 Irefrsh Iupd
2 3 0 100 0 1.5 1 1

* UNITS Npic Grid Stop SYMBOLS OUT
3 365 4 0 2 0

INPUTS 5

39,1 60,17 Qgain DmdELC DmdSOL
TMAINS(C) TsAVE(C) Qgain(KW) Delec(kW) Dsol(kW)

END

TRNSYS Deck of System Size #2 With Single Tank Configuration (w/ PV pump)

```

ASSIGN C:\KEARY\ANNUAL\SYS2B.LST 6
ASSIGN C:\KEARY\ANNUAL\Hsys2PVB.out 13
ASSIGN C:\KEARY\ANNUAL\WTHR91.DAT 14
ASSIGN C:\KEARY\ANNUAL\91DRAWS.dat 15
ASSIGN C:\KEARY\ANNUAL\MLKMAIN.DAT 16
ASSIGN C:\KEARY\ANNUAL\Dsys2PVB.OUT 17
ASSIGN C:\KEARY\ANNUAL\Msys2PVB.OUT 18
* SINGLE TANK for System #2B W/PV
* * * * *
*
*           Analysis of Average Water Loads
*           An Annual 1991 Analysis
*           for Demand Reduction of SDHW Systems
*           Milwaukee, WI WEPCo Utility
* * * * *
EQUATIONS 26
START=0.00
STOP=8760
STEP=1./6
TENV=18.0
TSET=60.0
*Solar TANK SIZE IN ACTUAL 80 GALLONS=>(3.7854*10^-3 m^3/1 gal)
OTSIZE=0.302832
*MODELLED SIZE IS 2/3 THE ORIGINAL DUE TO THE HEATING ELEMENT IN
*THE UPPER ONE THIRD OF TANK.
TSIZE=(2/3)*(OTSIZE)
OHGHT=1.2192
*SAME GOES FOR HEIGHT
HGHT=(2/3)*OHGHT
NODES=5
AREA=6.00
TI=6.9
*uloss is needed for the tank evaluation in kJ/HR-M2-C SO DIVIDE
*BY THE SURFACE AREA OF THE SOLAR GALLON TANK @ SAME STANDBY
LOSS
* WHICH YIELDS %/HR*DENS*Cp/2*PI*R*H =>KJ/HR-M2-C
OULOSS=3
* COMPENSATE FOR THE 1/3 RELATIVELY CONSTANT STANDBY LOSS
TERMS
* THAT AREN'T ACCOUNTED FOR IN THE 2/3 SIZE TANK
ULOSS=1.5*(OULOSS)
DAY=1.0
RHOG=2.0000E-01
SLOPE=2.30000E+01

```

GAMMAI=0.0000E+0
 SC=4871
 SHIFT=0.0
 LAT=3.85200E+01
 *TEMPERING VALVE EQUATIONS FOLLOW: SO WATER NOT MORE THAN
 TSET, IT
 *IS MIXED WITH MAINS TEMPERATURE TO DELIVERY AT TSET ONLY.
 * TMAINS IS FROM DATA READER 39 AND CHANGES MONTHLY
 $TDIFF = \text{MAX}(0.000001, ([60,5] - [39,1]))$
 $FLOWRATIO = \text{MIN}(1, ((TSET - [39,1]) / TDIFF))$
 $MLOAD = [29,1] * FLOWRATIO$
 FACT=3.7853
 SCALE=1.0*FACT
 *SCALE IS WHAT THE WATER DRAW IS SCALED BY=>NORMALLY 69.3
 GALLS
 *FACT IS THE CONVERSION FROM GAL/HOUR TO KG/HR

SIMULATION START STOP STEP
 Limits 25 25 25
 TOLERANCES 0.001 0.001
 WIDTH 72

UNIT 19 TYPE 9 DATA READER FOR MILKWAUKEE 1991 WEATHER
 * 1/1/91 TO 12/31/91 WEATHER
 PARAMETERS 20
 * MODE N dT(HOURS) DUMHOURS Tdb(C) T_wb(C) Wind I(kJ/M2-hr)
 -2 5 1 1 1 0 2 1 0 3 1 0 4 1 0 -5 1 0
 * LU FRMT
 14 0
 *OUTPUTS: 2,Tdb 5,I
 *TRACE 0,24

UNIT 29 TYPE 9 DATA READER FRO WATER DRAWS
 *WATER DRAWS: (GAL/HR) - CONVERT TO KG/HR
 * USE FACTOR 3.7853
 PARAMETERS 7
 * MODE N STEP VAR MULT ADD LU FRMT
 2 1 STEP -1 SCALE 0. 15 0
 *OUTPUTS: 1,DRAW(KG/HR)
 *TRACE 0,24

UNIT 39 TYPE 9 DATA READER FOR MILWAUKEE MAINS WATER
 TEMPERATURE
 * CHANGES MONTHLY BUT READ IN DAILY (24 HOURS) FROM F-CHART FILE
 PARAMTERS 8

* MODE N dT(HOURS) TMAINS LU FRMT
2 1 24 -1 1 0 16 0

*OUTPUTS: 1, TMAINS

UNIT 16 TYPE 16 RADIATION PROCESSOR

PARAMETERS 8

* RADMODE TRACKMODE TILTMODE DAY LAT SC SHIFT SMOOTH
3 1 1 DAY LAT SC SHIFT 2

INPUTS 6

* I(kJ/m2-hr) td1 td2 RHOG BETA1 GAMMAI INext 19,5 0.0
19,5 19,19 19,20 RHOG SLOPE GAMMAI 19,25
0.0 0.0 0.0 RHOG SLOPE GAMMAI 0.0

*OUTPUTS: 1,Io 2,THETAz 3,GAMMAz 4,I 5,Id 6,IT1 7,IbT1 8,IdT1 9,THETA1

* 10,BETA1 11,IT1

*TRACE 60,61

UNIT 1 TYPE 1 COLLECTOR

PARAMETERS 14

* MODE N AREA Cp EFFMODE G ao a1 a2 EFF CpHX OPTMODE bo b1
1 1 AREA 4.19 1 50.7 15. 0.0 -1 4.19 1 0.1 0.0

INPUTS 10

* Ti mCOLL(KG/HR) mHX Tamb It I Id RHOG THETA BETA(SLOPE)
3,1 3,2 3,2 19,2 16,6 16,4 16,5 0,0 16,9 16,10
TI 0.0 0.0 20.0 0.0 0.0 0.0 0.7 0.0 40.0

*OUPUTS: 1, To 2,mo 3,Qgain(KJ/HR) 4,Tco

*TRACE 60,61

UNIT 2 TYPE 2 PUMP CONTROLLER

PARAMETERS 4

* NSTK dThigh dTlow Tmax
11 1.0 1.0 100

INPUTS 4

* Th TI TIN GAMMAI
1,1 60,6 0,0 0,0
15. TI TI 0.

*OUTPUTS: 1,GAMMAo (CONTROL FUNCTION)

*TRACE 60,61

UNIT 3 TYPE 3 PUMP

PARAMETERS 4

* mMAX Cp Pmax(KJ/HR) fpar
325. 4.19 100. 0.

INPUTS 3

* Ti mi GAMMA
60,6 60,4 2,1

TI 0.0 0.0
 *OUTPUTS: 1,To 2,mo 3,Pfan

UNIT 60 TYPE 60 SOLAR STORAGE TANK

PARAMETERS 43

*NODES MODE VOL H PER H1IN H1OUT H2IN H2OUT CP
 NODES 1 TSIZE HGHT -1 0.00 HGHT HGHT 0 4.19
 *RHO Ut K KDELTA TBOIL AUXMODE HAUX1 HSTAT1 TSET1
 1000 ULOSS 2.0988 0. 100 2 0.75 0.75 TSET
 *Udb1 Ldb1 Qaux1 Haux2 HSTAT2 TSET2 Udb2 Ldb2 QAUX2
 2 2 0.0 0.495 0.495 TSET 2 2 0.00
 *UAflue Tflue HMODE Umode Hhx HXFLUID %GLY ID OD
 0.0 TENV 0 0 -0.1 1 0.60 0.1 0.3
 *HXAo FINFRAC FINEFF HX_L HX_K NOWARN
 0.86 0.73 0.8 4.9 1444 1

INPUTS 12

*M1IN M1OUT M2IN M2OUT TMAINS T2IN TENV GMA1 GMA2 HXIN MHX
 C_HX
 MLOAD MLOAD 1,2 0,0 39,1 1,1 0,0 0,0 0,0 0,0 0,0 0,0
 *29,1 29,1 1,2 0,0 39,1 1,1 0,0 0,0 0,0 0,0 0,0
 0.0 0.0 0.0 -2 6.9 TI TENV 1. 1. 71. -300 0.513

DERIVATIVES NODES

TI TI TI TI TI

*OUTPUTS: 1,MLOAD 2,MLOAD 3,Mcoll 4,Mcoll 5,Tload 6,Tcoll 7,Qenv
 * 8,Qin1 9,Qout1 10,Qin2 11,Qout2 12,Qaux2 13,Qaux1 14,Qaux2 15,Qflue
 * 16,deltaU 17,Tave 18,dPRESS 19,dPRESS 20,dPRESS 21,dPRESS 22,Qhx
 * 23,EB 24,TOUThx 25,LMTDhx 26,UAhx 27=>27+NODES=TNODES
 *TRACE 0,24

*UNIT 4 OUTPUTS:

*OUTPUTS: 1,Trtn 2,m_rtnCOLL 3,Tload 4,m_load 5,Qenv,loss 6,Qs
 * 7,dEtank 8,Qaux1

UNIT 6 TYPE 6 BACK-UP HEATER FOR SOLAR

PARAMETERS 5

* Qmax(KJ/HR) Tset(C) Cp(KJ/KG-C) UAloss(kJ/hr-C) EFFhtr
 9999999. TSET 4.19 0 1

INPUTS 4

* Ti(C) mi(KG/HR) GAMMA Tenv
 60,5 60,1 0,0 0,0
 TI 0.0 1. 21.0

*OUTPUTS: 1,To 2,mo 3,Qaux(KJ/HR) 4,Qloss 5,Qfluid(kJ/hr)

EQUATIONS 10

*CONVERTING KJ/HR TO KW FOR DEMAND & KG/HR TO GPM WATER DRAW
 *FOR FIRST 2 TRIPLE DAYS (0-144) USE FACTOR 3.7853, FOR SINGLE STAT
 DRAW=[29,1]/SCALE
 PFAN=[3,3]/3600
 GAMPUMP=[2,1]
 DmdSOL=([6,3])/3600
 QauxSOL=([6,3])
 QenvLOSS=[60,7]/3600
 QsTANK=([60,10]-[60,11])/3600
 Qsolar=[16,4]/3600
 Qgain=[1,3]/3600
 DRAWS=[29,1]/3.7853
 *PRINTS GALLONS/HOUR

*****HOURLY RESULTS*****

UNIT 42 TYPE 24 INTEGRATOR FOR HOURLY ENERGY AND DEMAND SAVINGS

* PARAMETERS 1: dtR=>TIME INTERVAL FOR Xi'S TO BE INTEGRATED

* Yi's ARE RESET TO 0 AFTER EACH TIME INTERVAL

PARAMETERS 1

* TIME PERIOD TO INTEGRATE OVER

1.0

INPUTS 2

* QauxSOL DRAWS

QauxSOL DRAW

0.0 0.0

*OUTPUTS: 1,QauxSOLhourly 2,QauxELHourly

EQUATIONS 1

* HOURLY DEMAND OF SOLAR & ELECTRIC BACKUP

SOLdmd=([42,1]/3600)

UNIT 28 TYPE 25 HOURLY RESULTS PRINTER

*PRINT RUNNING TOTALS DEMAND EVERY HOURS

PARAMETERS 4

* dtp tON tOFF Lunit UNITS

1 START STOP 13

INPUTS 1

SOLdmd

SOLdmd(kW)

*****DAILY RESULTS*****

UNIT 24 TYPE 24 INTEGRATOR FOR DAILY ENERGY SAVINGS

* PARAMETERS 1: dtR=>TIME INTERVAL FOR Xi'S TO BE INTEGRATED

* Yi's ARE RESET TO 0 AFTER EACH TIME INTERVAL

PARAMETERS 1

* TIME PERIOD TO INTEGRATE OVER
24.0

INPUTS 2

* QauxSOL DRAWS
 QauxSOL DRAWS
 0.0 0.0

*OUTPUTS: 1,QauxSOLdaily 2,QauxELCdaily
*TRACE 0,24

UNIT 25 TYPE 25 DAILY RESULTS PRINTER

*PRINT RUNNING TOTALS OF INTEGRATION RESULTS EVERY 24 HOURS

PARAMETERS 4

* dtp tON tOFF LU UNITS
 24 START STOP 17

INPUTS 2

* QauxSOLDAILY DRAWS
 24,1 24,3
 QauxSOL(kJ/DAY) DRAWS(GAL/DAY)

*****MONTHLY RESULTS*****

UNIT 22 TYPE 24 INTEGRATOR FOR MONTHLY ENERGY SAVINGS

* PARAMETERS 1: dtR=>TIME INTERVAL FOR Xi'S TO BE INTEGRATED
* Yi's ARE RESET TO 0 AFTER EACH TIME INTERVAL

PARAMETERS 1

* TIME PERIOD TO INTEGRATE OVER
 -1

INPUTS 2

* QauxSOL
 QauxSOL DRAWS
 0.0 0.0

*OUTPUTS: 1,QauxSOLmonthly 2,QauxELCmonthly

UNIT 52 TYPE 25 MONTHLY RESULTS PRINTER

*PRINT RUNNING TOTALS OF INTEGRATION RESULTS EVERY MONTH

PARAMETERS 4

* dtp tON tOFF LU UNITS
 -1 START STOP 18

INPUTS 2

* QauxSOLDAILY DRAWS
 22,1 22,3
 QauxSOL(kJ/DAY) DRAWS(GPH)

END

UNIT 65 TYPE 65 ON-LINE GRAPHICS

PARAMETERS 14

* Ntop Nbot Ymin1 Ymax1 Ymin2 Ymax2 Irefrsh Iupd

3 2 0 5000 0 1.5 1 1

* UNITS Npic Grid Stop SYMBOLS OUT

3 365 4 0 2 0

INPUTS 5

19,5,16,1 1,3 DmdELC DmdSOL

WEATHRAD PROCCED Qgain(KJ/HR) Delec(kW) Dsol(kW)

end

UNIT 65 TYPE 65 ON-LINE GRAPHICS

PARAMETERS 14

* Ntop Nbot Ymin1 Ymax1 Ymin2 Ymax2 Irefrsh Iupd

2 3 0 100 0 1.5 1 1

* UNITS Npic Grid Stop SYMBOLS OUT

3 365 4 0 2 0

INPUTS 5

39,1 60,17 Qgain DmdELC DmdSOL

TMAINS(C) TsAVE(C) Qgain(KW) Delec(kW) Dsol(kW)

END

TRNSYS Deck of System Size #2 With 60 Gallon GAS Two-Tank Configuration

```

ASSIGN C:\KEARY\ANNUAL\SYS2GAS.LST 6
ASSIGN C:\KEARY\ANNUAL\WTHR91.DAT 14
ASSIGN C:\KEARY\ANNUAL\91DRAWS.dat 15
ASSIGN C:\KEARY\ANNUAL\MLKMAIN.DAT 16
ASSIGN C:\KEARY\ANNUAL\Msys2GAS.OUT 18
* 60 GALLON GAS TANK B.U. for System #2 W/PV
* * * * *
*
*           Analysis of Average Water Loads
*           An Annual 1991 Analysis
*           for Demand Reduction of SDHW Systems
*           Milwaukee, WI WEPCo Utility
* * * * *
EQUATIONS 26
START=0.00
STOP=8760
STEP=1./6
TENV=18.0
TSET=60.0
*Solar TANK SIZE IN ACTUAL 80 GALLONS=>(3.7854*10^-3 m^3/1 gal)
TSIZE=0.302832
HGHT=1.2192
NODES=5
AREA=6.00
TI=6.9
*uloss is needed for the tank evaluation in kJ/HR-M2-C SO DIVIDE
*BY THE SURFACE AREA OF THE SOLAR GALLON TANK @ SAME STANDBY
LOSS
* WHICH YIELDS %/HR*DENS*Cp/2*PI*R*H =>KJ/HR-M2-C
ULOSS=3
*fractional loss is the (%/hour) rating for different dhw's
FRCTLOSS=3.5
*STANDBYLOSS=FRCLOSS(%/HR)/100%*VOL(GAL)*8.34(LB/GAL)*T(F)*1(BTU/
LB-F)
*STNDBY=KJ/HOUR =>(%/HR)/(%)*VOL(M3)*DENS(KG/M3)*T(C)*Cp(KJ/KG-C)
*THE bACK-UP TANK SIZE IS 60 GALLONS, WITH ITS ASSOCIATED LOSSES
BUTSIZE=0.227124
STBYLOSS=(FRCTLOSS/100)*(BUTSIZE)*1000*(TSET-TENV)*4.19
DAY=1.0
RHOG=2.0000E-01
SLOPE=2.30000E+01
GAMMAI=0.0000E+0
SC=4871

```


SHIFT=0.0
 LAT=3.85200E+01
 *TEMPERING VALVE EQUATIONS FOLLOW: SO WATER NOT MORE THAN
 TSET, IT
 *IS MIXED WITH MAINS TEMPERATURE TO DELIVERY AT TSET ONLY.
 * TMAINS IS FROM DATA READER 39 AND CHANGES MONTHLY
 $TDIFF = \text{MAX}(0.000001, ([60,5] - [39,1]))$
 $FLOWRATIO = \text{MIN}(1, ((TSET - [39,1]) / TDIFF))$
 $MLOAD = [29,1] * FLOWRATIO$
 FACT=3.7853
 SCALE=1.0*FACT
 *SCALE IS WHAT THE WATER DRAW IS SCALED BY=>NORMALLY 69.3
 GALLS
 *FACT IS THE CONVERSION FROM GAL/HOUR TO KG/HR

SIMULATION START STOP STEP

Limits 25 25 25
 TOLERANCES 0.001 0.001
 WIDTH 72

UNIT 19 TYPE 9 DATA READER FOR MILKWAUKEE 1991 WEATHER

* 1/1/91 TO 12/31/91 WEATHER
 PARAMETERS 20
 * MODE N dT(HOURS) DUMHOURS Tdb(C) T_wb(C) Wind I(kJ/M2-hr)
 -2 5 1 1 1 0 2 1 0 3 1 0 4 1 0 -5 1 0
 * LU FRMT
 14 0
 *OUTPUTS: 2,Tdb 5,I
 *TRACE 0,24

UNIT 29 TYPE 9 DATA READER FRO WATER DRAWS

*WATER DRAWS: (GAL/HR) - CONVERT TO KG/HR
 * USE FACTOR 3.7853
 PARAMETERS 7
 * MODE N STEP VAR MULT ADD LU FRMT
 2 1 STEP -1 SCALE 0. 15 0
 *OUTPUTS: 1,DRAW(KG/HR)
 *TRACE 0,24

UNIT 39 TYPE 9 DATA READER FOR MILWAUKEE MAINS WATER TEMPERATURE

* CHANGES MONTHLY BUT READ IN DAILY (24 HOURS) FROM F-CHART FILE
 PARAMTERS 8
 * MODE N dT(HOURS) TMAINS LU FRMT
 2 1 24 -1 1 0 16 0

*OUTPUTS: 1, TMAINS

UNIT 16 TYPE 16 RADIATION PROCESSOR

PARAMETERS 8

* RADMODE TRACKMODE TILTMODE DAY LAT SC SHIFT SMOOTH

3 1 1 DAY LAT SC SHIFT 2

INPUTS 6

* I(kJ/m2-hr) td1 td2 RHOG BETA1 GAMMAI INext 19,5 0.0

19,5 19,19 19,20 RHOG SLOPE GAMMAI 19,25

0.0 0.0 0.0 RHOG SLOPE GAMMAI 0.0

*OUTPUTS: 1,Io 2,THETAz 3,GAMMAz 4,I 5,Id 6,IT1 7,IbT1 8,IdT1 9,THETA1

* 10,BETA1 11,IT1

*TRACE 60,61

UNIT 1 TYPE 1 COLLECTOR

PARAMETERS 14

* MODE N AREA Cp EFFMODE G ao a1 a2 EFF CpHX OPTMODE bo b1

1 1 AREA 4.19 1 50.7 15. 0.0 -1 4.19 1 0.1 0.0

INPUTS 10

* Ti mCOLL(KG/HR) mHX Tamb It I Id RHOG THETA BETA(SLOPE)

3,1 3,2 3,2 19,2 16,6 16,4 16,5 0,0 16,9 16,10

TI 0.0 0.0 20.0 0.0 0.0 0.0 0.7 0.0 40.0

*OUPUTS: 1, To 2,mo 3,Qgain(KJ/HR) 4,Tco

*TRACE 60,61

UNIT 2 TYPE 2 PUMP CONTROLLER

PARAMETERS 4

* NSTK dThigh dTlow Tmax

11 1.0 1.0 100

INPUTS 4

* Th TI TIN GAMMAI

1,1 60,6 0,0 0,0

15. TI TI 0.

*OUTPUTS: 1,GAMMAo (CONTROL FUNCTION)

*TRACE 60,61

UNIT 3 TYPE 3 PUMP

PARAMETERS 4

* mMAX Cp Pmax(KJ/HR) fpar

325. 4.19 100. 0.

INPUTS 3

* Ti mi GAMMA

60,6 60,4 2,1

TI 0.0 0.0

*OUTPUTS: 1,To 2,mo 3,Pfan

UNIT 60 TYPE 60 SOLAR STORAGE TANK

PARAMETERS 43

```
*NODES MODE VOL H PER H1IN H1OUT H2IN H2OUT CP
NODES 1 TSIZE HGHT -1 0.00 HGHT HGHT 0 4.19
*RHO Ut K KDELTA TBOIL AUXMODE HAUX1 HSTAT1 TSET1
1000 ULOSS 2.0988 0. 100 2 1.155 1.155 TSET
*Udb1 Ldb1 Qaux1 Haux2 HSTAT2 TSET2 Udb2 Ldb2 QAUX2
2 2 0.0 0.495 0.495 TSET 2 2 0.00
*UAflue Tflue HMODE Umode Hhx HXFLUID %GLY ID OD
0.0 TENV 0 0 -0.1 1 0.60 0.1 0.3
*HXAo FINFRAC FINEFF HX_L HX_K NOWARN
0.86 0.73 0.8 4.9 1444 1
```

INPUTS 12

```
*M1IN M1OUT M2IN M2OUT TMAINS T2IN TENV GMA1 GMA2 HXIN MHX
C_HX
MLOAD MLOAD 1,2 0,0 39,1 1,1 0,0 0,0 0,0 0,0 0,0 0,0
*29,1 29,1 1,2 0,0 39,1 1,1 0,0 0,0 0,0 0,0 0,0
0.0 0.0 0.0 -2 6.9 TI TENV 1. 1. 71. -300 0.513
```

DERIVATIVES NODES

```
TI TI TI TI TI
```

```
*OUTPUTS: 1,MLOAD 2,MLOAD 3,Mcoll 4,Mcoll 5,Tload 6,Tcoll 7,Qenv
* 8,Qin1 9,Qout1 10,Qin2 11,Qout2 12,Qaux2 13,Qaux1 14,Qaux2 15,Qflue
* 16,deltaU 17,Tave 18,dPRESS 19,dPRESS 20,dPRESS 21,dPRESS 22,Qhx
* 23,EB 24,TOUThx 25,LMTDhx 26,UAhx 27=>27+NODES=TNODES
*TRACE 0,24
```

*UNIT 4 OUTPUTS:

```
*OUTPUTS: 1,Trtn 2,m_rtnCOLL 3,Tload 4,m_load 5,Qenv,loss 6,Qs
* 7,dEtank 8,Qaux1
```

UNIT 6 TYPE 6 BACK-UP HEATER FOR SOLAR

PARAMETERS 5

```
* Qmax(KJ/HR) Tset(C) Cp(KJ/KG-C) UAloss(kJ/hr-C) EFFhtr
9999999. TSET 4.19 0 0.7
```

INPUTS 4

```
* Ti(C) mi(KG/HR) GAMMA Tenv
60,5 60,1 0,0 0,0
TI 0.0 1. 21.0
```

```
*OUTPUTS: 1,To 2,mo 3,Qaux(KJ/HR) 4,Qloss 5,Qfluid(kJ/hr)
```

```
* THIS HEATER IS THE MODEL FOR THE ELECTRIC ONLY TANK
```

```
* MAINS IS HEATED WITH NO STORAGE, LOSSES ARE ACCOUNTED FOR
WITH THE
```

```
* STANDBY LOSS TERM
```

UNIT 61 TYPE 6 HEATER

PARAMETERS 5

* Qmax(KJ/HR) Tset(C) Cp(KJ/KG-C) UAloss(kJ/hr-C) EFFhtr
 9999999. TSET 4.19 0 0.7

INPUTS 4

* Ti(C) mi(KG/HR) GAMMA Tenv
 39,1 29,1 0,0 0,0
 8.0 0.0 1. 18.0

*OUTPUTS: 1,To 2,mo 3,Qaux(KJ/HR) 4,Qloss 5,Qfluid(kJ/hr)

EQUATIONS 16

*CONVERTING KJ/HR TO KW FOR DEMAND & KG/HR TO GPM WATER DRAW

*FOR FIRST 2 TRIPLE DAYS (0-144) USE FACTOR 3.7853, FOR SINGLE STAT

DRAW=[29,1]/SCALE

PFAN=[3,3]/3600

GAMPUMP=[2,1]

DmdSOL=([6,3]+STBYLOSS)/3600

DmdELC=([61,3]+STBYLOSS)/3600

dTANKLOSS=STBYLOSS/3600

QauxSOL=([6,3]+STBYLOSS)

QauxELC=([61,3]+STBYLOSS)

QTHERM=QauxELC*(0.9478/100000)

QSGAS=QauxELC*(0.9478/100000)

SF=((QauxELC-QauxSOL)/(QauxELC+0.00000001))*100

*Qaux1=[60,13]/3600

QenvLOSS=[60,7]/3600

QsTANK=([60,10]-[60,11])/3600

Qsolar=[16,4]/3600

Qgain=[1,3]/3600

DRAWS=[29,1]/3.7853

*PRINTS GALLONS/HOUR

*****MONTHLY RESULTS*****

UNIT 22 TYPE 24 INTEGRATOR FOR MONTHLY ENERGY SAVINGS

* PARAMETERS 1: dtR=>TIME INTERVAL FOR Xi'S TO BE INTEGRATED

* Yi's ARE RESET TO 0 AFTER EACH TIME INTERVAL

PARAMETERS 1

* TIME PERIOD TO INTEGRATE OVER

-1

INPUTS 5

* QauxSOL QauxELC

QauxSOL QauxELC DRAWS QTHERM QSGAS

0.0 0.0 0.0 0.0 0.0

*OUTPUTS: 1,QauxSOLmonthly 2,QauxELCmonthly

EQUATIONS 1

SFMONTHLY=100*([22,2]-[22,1])/([22,2]+0.000000001)

UNIT 52 TYPE 25 MONTHLY RESULTS PRINTER

*PRINT RUNNING TOTALS OF INTEGRATION RESULTS EVERY MONTH

PARAMETERS 4

* dtp tON tOFF LU UNITS

-1 START STOP 18

INPUTS 6

* QauxSOL QauxELCD SFRACTION DRAWS

22,1 22,2 SFMONTHLY 22,3 22,4 22,5

QauxSOLkJ QauxELckJ SF(%) DRAWS QTHERM QSGAS

END

UNIT 65 TYPE 65 ON-LINE GRAPHICS

PARAMETERS 14

* Ntop Nbot Ymin1 Ymax1 Ymin2 Ymax2 Irefrsh Iupd

3 2 0 5000 0 1.5 1 1

* UNITS Npic Grid Stop SYMBOLS OUT

3 365 4 0 2 0

INPUTS 5

19,5, 16,6 1,3 DmdELC DmdSOL

WEATHRAD PROCCED Qgain(KJ/HR) Delec(kW) Dsol(kW)

end

UNIT 65 TYPE 65 ON-LINE GRAPHICS

PARAMETERS 14

* Ntop Nbot Ymin1 Ymax1 Ymin2 Ymax2 Irefrsh Iupd

2 3 0 100 0 1.5 1 1

* UNITS Npic Grid Stop SYMBOLS OUT

3 365 4 0 2 0

INPUTS 5

39,1 60,17 Qgain DmdELC DmdSOL

TMAINS(C) TsAVE(C) Qgain(KW) Delec(kW) Dsol(kW)

END